



GOVERNMENT OF NAGALAND
STATE WATER QUALITY TESTING LABORATORY
PHED, DIMAPUR: NAGALAND

No. PHE/S/LAB/DWC/2016/089

Date: 20-01-2024

TO WHOM IT MAY CONCERN

This is to certify that water sample received from **Delhi Public School, Dimapur** collected from filter source located at Darogapathar, 2^{1/2} Mile, Dimapur Nagaland has been analysed at *State Water Quality Testing Laboratory, PHED Dimapur: Nagaland* on 18th of January 2024, and found that value of the test results are within the desirable limit as per IS 10500:2012 for the parameters analysed.

The test report is attached herewith and relates only to the tested sample.

The above condition is valid for the period of **6 (six) months** from the date of issue.



Achit
18/1/2024
PRINCIPAL
DELHI PUBLIC SCHOOL
DIMAPUR : NAGALAND

[Signature]
(A ROLLAND KIKON)
Quality Manager (Chemist)
State Water Quality Testing Laboratory
PHED: Dimapur, Nagaland
State Water Quality Testing Laboratory
PHED, Dimapur: Nagaland



GOVERNMENT OF NAGALAND
STATE WATER QUALITY TESTING LABORATORY
PHED, DIMAPUR: NAGALAND

Test Report

Sample ID No.	0124009
Date of sample collection:	18/01/24
Date of sample delivery at the Lab:	18/01/24
Customer Name and Address:	Delhi Public School, Dimapur
Test Commenced on :	18/01/24
Test Completed on:	20/01/24
SAMPLE DETAILS FURNISHED BY CUSTOMER	
Source:	Filter water
Location:	Darogapathar, 2 ^{1/2} Mile, Dimapur, Nagaland
Sample collected by:	Customer
Quantity Received:	4.0 Ltr
Sample Container:	Plastic Bottle
Condition of Sample:	Acceptable condition

The test result of sample received is as follow.

Sl. No	PARAMETERS	BIS 10500:2012 Unit -Desirable limit	Permissible limit	Test Method	Test Report
1	Color	5 Hazen Unit	15 Hazen Unit	APHA 23 rd Edition 2120 B	02
2	Odor	Agreeable	Agreeable	Qualitative	Agreeable
3	Tastes	Agreeable	Agreeable	Qualitative	Agreeable
4	pH at 25°C	6.5-8.5	No relaxation	APHA23 rd Edition 4500 -H ⁺ B	6.59
5	Turbidity	1 NTU	5 NTU	APHA23 rd Edition 2130 B	0.09
6	Total Dissolved Solids mg/L	500 mg/L	2000 mg/L	APHA23 rd Edition 2540 C	57
7	Total Hardness	200 mg/L as CaCO ₃	600 mg/L as CaCO ₃	APHA23 rd Edition 2340 C	60
8	Calcium	75 mg/L as CaCO ₃	200 mg/L as CaCO ₃	APHA23 rd Edition 3500-Ca-B	24
9	Magnesium	30 mg/L as Mg	100 mg/L as Mg	APHA23 rd Edition 3500-Mg	8.7
10	Total Alkalinity	200 mg/L as CaCO ₃	600 mg/L as CaCO ₃	APHA23 rd Edition 2320 B	20
11	Chloride	250 mg/L as Cl	1000 mg/L as Cl	APHA23 rd Edition 4500-Cl ⁻ B	5.9
12	Iron	1.0 mg/L as Fe ⁺²	No relaxation	Photometer (Palintest- 7100)	0.14
13	Nitrate	45 mg/L as NO ₄	No relaxation	Photometer (Palintest- 7100)	3.1
14	Fluoride	1.0 mg/L	1.5 mg/L	Photometer (Palintest- 7100)	0.34
15	Sulphate	200 mg/L as SO ₄	400 mg/L	Photometer (Palintest- 7100)	05
16	Bacteriological Contamination	Negative	Negative	H ₂ S vial Strip Test	-ive

Prepared & Verified by



[Signature]
Authorized Signatory
A. Rolland Kikon
Quality Manager (Chemist)
SWQTL, PHED, Dimapur, Nagaland
State Water Quality Testing Laboratory
PHED, Dimapur, Nagaland

Note:
NA- Not Available
BDL -Below Detection Level, NT- Not Tested
The test results relates only to the tested sample.
The report shall not be produced in full or part without the written approval of Quality Manager, SWQTL, PHED, Dimapur, Nagaland.
The test report is valid for the period of six (6) months.

End of Report

[Signature]
PRINCIPAL
DELHI PUBLIC SCHOOL
DIMAPUR : NAGALAND

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DWC/5/LAM/DWC/2016/089

Dated: 20.01.21

It is certified that an inspection team headed by A. Rolland Kikon, Chemist

(Name of Officers with designation) from State Laboratory, PHED, Dimapur

(Name of Department/ Office) inspected the D.P.S., Dimapur

(Name & Address of the school) on 18.01.21.....(date of inspection) and found that the D.P.S., Dimapur.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of Six (6) months

Signature with Seal [Signature]

Name : A. Rolland Kikon

Designation : Chemist

Name & Address of the Office / Department Chemist, State Laboratory, PHED, Dimapur, Nagaland

To The Principal
D.P.S., Dimapur

(Name & Address of the Institution)



State Water Quality Testing Laboratory
PHED, Dimapur, Nagaland

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

[Signature]
07/2/2021
PRINCIPAL
DELHI PUBLIC SCHOOL
DIMAPUR : NAGALAND